

DETAILED ENERGY AUDIT REPORT

Year-2022-2023



GOVT. P.G. COLLEGE

Madhav Rao Schindia Road, Dist.-Guna (M.P.) Pin code 473001

CONDUCTED BY:

SEES ENERGY SOLUTION



296, Shivampuri Colony, Vishal Urban Block A, Flat No. 204, Indore (M.P.)-452001

Email Address: seesenergysolutions@gmail.com

Contact number: 98275 78219



| | |
|---|--|
| Project Title: | Detailed Energy Audit |
| Organization: | SEES ENERGY SOLUTION. |
| Client: | Govt. P.G. College , Guna - 473001 Madhya Pradesh, India. |
| Prepared By | |
| 1. Mr. Rambabu Raghuvanshi (Certified Energy Auditor) 2. Mr. Harshal Mahajan (Energy Consultant) | |

SEES ENERGY SOLUTION, INDORE

MR. RAMBABU RAGHUWANSHI
EA-29059
Certified Energy Auditor



Acknowledgement

SEES ENERGY SOLUTION. expresses sincere thanks to the management of **Govt. PG College, Guna** for inviting SEES ENERGY SOLUTION. Conducts comprehensive Energy Audit 2022-2023 of their Premises at **Govt. PG College, Guna**. The field study of this audit was carried out on 30-Sep-2023.

The officials of **Govt. PG College, Guna** have coordinated and helped to the audit team during the field study and measurement. SEES ENERGY SOLUTION .express special thanks to the following persons of Govt. Girls College, Indore.

| Internal Audit Team | | |
|---------------------|------------------------|-----------------------|
| 1 | Principal | Dr. B.K. Tiwari |
| 2 | IQAC& NACC Coordinator | Dr. Archana Shrotriya |

We are also thankful to all other Teachers and staffs for the keen interest shown in this study and the courtesy extended. We are thankful to the management for giving us the opportunity to be involved in this very interesting and challenging project.

We would be happy to provide any further clarifications, if required, to facilitate implementation of the recommendations.

SEES ENERGY SOLUTION, INDORE

MR. RAMBABU RAGHUWANSHI
EA-29059
Certified Energy Auditor



ENERGY AUDIT Certificate



This is to certify that **GOVT. P.G. COLLEGE, GUNA** has conducted, Energy audit in the academic year 2022 - 2023 to assess the energy initiative planning, efforts, activities, implemented in the college campus like Light , Fan, pump, electrical load , Conservation of Energy, Energy Management and various Environmental Awareness activities. **SEES ENERGY SOLUTION** has verified campus data of **GOVT. P.G. COLLEGE, GUNA** This Energy Audit are also aimed to assess impact of Energy saving initiatives for maintenance of the campus eco-friendly.

Mr. Rambabu Raghuwanshi

EA-29059
Bureau of Energy efficiency
Ministry of Power Govt. of India



List of Contents

Table of Contents

| | |
|---|-----------|
| EXECUTIVE SUMMARY..... | 8 |
| Summary of Energy Conservation Measures..... | 11 |
| CHAPTER-1 | 14 |
| INTRODUCTION | 14 |
| 1.1 Energy Audit..... | 14 |
| 1.2 Methodology & Approach | 14 |
| 1.3 Instruments used in Energy Audit:..... | 15 |
| CHAPTER-2 | 16 |
| 2.1 College Details..... | 16 |
| 2.2 Site visit and field inspection | 16 |
| 2.3 Power Measurement..... | 18 |
| CHAPTER-3 | 19 |
| 3.1 Month Wise Energy Consumption..... | 19 |
| 3.2 Observations & Comments: | 23 |
| CHAPTER - 4 | 24 |
| LIGHTING SYSTEM | 24 |
| 4.1 Lighting Fixtures:..... | 24 |
| 4.2 Observations & Comments: | 26 |
| CHAPTER-5 | 28 |
| FAN SYSTEM..... | 28 |
| 5.1 Details of Different type off fans: | 28 |
| 5.2 Observations & Comments: | 30 |
| CHAPTER - 6 | 32 |
| OTHER EQUIPMENTS LOAD | 32 |
| 6.1 Different Type Other Equipment's | 32 |
| 6.2 Observations & Comments: | 32 |
| CHAPTER -7 | 33 |
| PUMPING SYSTEM..... | 33 |
| Pumps Details: | 33 |
| 7.1 Submersible Pumps..... | 33 |
| 7.2 Observation and Comments:..... | 33 |
| CHAPTER-08 | 34 |
| <u>ANNEXURE</u> | |



List of Table

| | |
|--|----|
| Table 1. Connected Load (kW) | 9 |
| Table 2. Lighting Saving Highlights | 11 |
| Table 3. Summary of Energy Conservation Measures..... | 11 |
| Table 4 Electricity Bill -1 Govt. P.G. College, IVRS- N2419054591 | 20 |
| Table 5 Electricity Bill -2 Govt. P.G. College, Guna IVRS- N2419058383 | 21 |
| Table 6 Electricity Bill -2 Govt. PG College, Guna IVRS-N2419014551 | 22 |
| Table 7. Different type of lighting fixture:..... | 24 |
| Table 8. Different type of Fan | 28 |
| Table 9. Different type of equipment system | 32 |
| Table 10. Major usage area of pump | 33 |

List of figures

| | |
|---|----|
| Figure 1. Connected Load details of campus in different zone..... | 9 |
| Figure 2. Law College Building | 17 |
| Figure 3. B-Block & Library Building..... | 17 |
| Figure 4. Lux Level Reading Measurement at site | 17 |
| Figure 5. Different Meters in College Building | 18 |
| Figure 6. Electricity Tariff 2022-23 | 19 |
| Figure 7. Per Unit Charges of IVRS-N2419054591 | 20 |
| Figure 8. Per Unit Charges of IVRS-N2419058383 | 21 |
| Figure 9. Per Unit Charges of IVRS-N2419014551 | 22 |



ABBREVIATION

| | |
|----------|---|
| O&M | Operation and Maintenance |
| kW | Kilo Watt |
| P.F | Power Factor |
| kVA | kilo Volt Ampere |
| kWh | kilowatt Hour |
| kVAh | kilovolt Amperes Hour |
| kVAr | kilovolt Amperes Reactive |
| ACs | Air Conditioners |
| FTL | Fluorescent Tube Light Lamp |
| TR | Ton of Refrigeration |
| SPC | Specific Power Consumption |
| CMH | Cubic Meter per Hour |
| STL | Single Tube Light |
| DTL | Double Tube Light |
| Amp | Ampere |
| Volt | Voltage |
| BLDC | Brushless Direct current |
| Nos | Numbers |
| Hrs | Hours |
| MPMKVVCL | Madhya Pradesh Madhya Kshetra Vidyut Vitaran Company Ltd. |



EXECUTIVE SUMMARY

College Details:

| Particulars | Units | Details |
|-----------------------------------|----------|---------------------|
| Name of the College | - | Govt. P.G. College. |
| Location | - | GUNA (M.P), India |
| Owner | - | Government |
| Contact Person | - | Dr. B.K. Tiwari |
| No. of Shifts | Nos. | 1 |
| Daily Operating Hours | Hrs./day | 8 |
| Annual Working Days | Days/yr. | 300 |
| Source of Electricity | - | MPPKVVCL |
| Total connected maximum Load | (kW) | 83 kW |
| Total Sanctioned Load | (kW) | 81 kW |
| Average Energy Charge in per unit | Rs. /kWh | 10.00 |



a) Existing Major Energy Consuming Technology and Electricity billing analysis:

The major equipment's installed in **Govt. PG College, Guna.** like Lighting fixtures, Fans and Other appliances.

Table 1. Connected Load (kW)

| S.No. | Type of Electrical System | Connected Load Power (kW) | Connected Load (%) |
|-----------------------------|---------------------------|---------------------------|--------------------|
| 1 | Lighting System | 12.81 | 15.38% |
| 2 | Fan System | 31.24 | 37.52% |
| 3 | Air conditioning System | 17 | 20.42% |
| 4 | Water Pumping | 4.50 | 5.41% |
| 5 | Other Appliances | 17.71 | 21.27% |
| Total Connected Load | | 83.26 | |




Figure 1. Connected Load details of campus in different zone

- It is observed and analyzed that there are **8 major connection of total sanction load is 81 kW** in College premises.
- As per electricity bills observation and analysis is from **electricity unit (kWh) 92067 kWh** for electricity bill in college premises.
- As per electricity bills observation and analysis **Total 12-month bill Paid is & Rs. 832447.**
- As per electricity bills observation and analysis, **electricity bill Power Factor varies from 0.80-0.99, can be monitor & improve.**

Note – Please maintain electricity bill logbook properly in record for monitoring and analysis.



b) Proposed Energy Saving Technologies with Cost Economics.

+ LIGHTING SYSTEM

- We appreciate to use **LED Lighting luminaries** at some location as per site visit.
- We observed during visit, few Lights were FTL tube light consuming high electricity.
- We are suggesting to purchases all electrical equipment as per star leveling program by Bureau of energy. Efficiency, and will get huge amount of electricity saving.
- We are suggesting conducting regular **Cleaning and maintenance of lighting fixtures** in every 5-6 months. To increase performance of Lighting and also improve their Lux level.
- We will get energy saving approximately **5544 kWh** per year and also will get amount saving approximately **Rs. 5544** per year by replacing conventional T5 Tube light with new energy efficient LED Tube light .
- As per data collection and site visit, Total Connected lighting load at College Campus is **12.80 kW**.
- As per data collection and observation, **Total no. of lighting fixture is 557**.

+ Ceiling Fan System

- We observed that most of the Fans installed in campus were conventional.
- We are recommended to **replace 444 no. of 70 W Ceiling fan with New Super energy efficient 5 star rated BLDC ceiling fan** and will get huge amount of electricity saving as per Star leveling program by Bureau of Energy Efficiency.
- We are **Suggesting to purchases new energy efficient BLDC fan as per Star leveling program by Bureau of Energy Efficiency, and will get huge amount of electricity saving.**
- Energy Saving calculation **and recommendation for the existing Conventional** Ceiling fans with BLDC super energy efficient fan has been given in this report.
- We are suggesting **conducting regular Cleaning and maintenance** of Fan at least in every 6 months to increase performance of Fan.
- We are also suggesting improving their Air delivery of Fan by Replacing New energy efficient BLDC Fan as per 5 stars leveling of Bureau of energy efficiency.
- We will get energy saving approximately **44755 kWh** per year and also will get amount saving approximately **Rs. 447552.00** per year by replacing conventional Fan with new energy efficient BLDC fan.
- The total load for Ceiling Fan is **31.24 kW**.
- Total No. of Fan fixtures are **444**.

+ Pumping System

- We observed during Energy Audit and site visit, **1 Pump of Capacity 3 HP were installed** within college campus for drinking water, Flushing and gardening purpose.
- Power consumption of each **3 HP** pump was **4.50 kW** as per site visit and measurement.
- We are suggesting purchasing **5 star rated pumps and will get huge** amount of saving as per Star leveling program by Bureau of Energy Efficiency 2020.
- We are **suggesting installing Solar Pumping system and** will get huge amount of savings.



+ Other Different Type of Connected Load:

There are different types of other equipment's like Computer, Printer, Xerox machine, Water Cooler, Refrigerator and other lab equipment's are installed at various location and they also contribute electricity consumption

- We suggest to **purchase equipment's as per Star leveling program** by Bureau of Energy Efficiency 2020, and will get huge amount of electricity saving.
- Maintenance of all the equipment's should be done regularly.

c) Saving Highlights

Table 2. Lighting Saving Highlights

| | | |
|--------------------------------------|--------------|--------------------|
| Total Amount of savings (kWh) | 50299 | kWh |
| Total Amount of savings Rs | 5.02 | Rs. In Lacs |
| Total Amount of investments | 12.95 | Rs. In Lacs |
| Pay Back Period | 22 | Months |

Summary of Energy Conservation Measures

Table 3. Summary of Energy Conservation Measures

| S.No. | Energy Conservation Measures | Annual Savings | | Investment | Payback |
|-----------------------|---|----------------|--------|------------|---------|
| | | kWh | Rs. | Rs. | Months |
| LED TUBE LIGHT | | | | | |
| 1 | Replace 105 no of Existing 40 W FTL Tube light with Energy efficient 18 W LED Tube light. | 5544 | 55440 | 52500 | 11 |
| CEILING FAN | | | | | |
| 2 | Replace 444 no of Existing 70 W Ceiling Fan with Energy efficient Energy Efficient 28 W BLDC Ceiling Fan. | 44755 | 447552 | 1243200 | 33 |
| | | 50299 | 502992 | 1295700 | 22 |



CHAPTER-1

INTRODUCTION

1.1 Energy Audit

Energy Audit is an effective means of establishment present efficiency levels and identifying Potential areas of improvement in energy consumption.

Energy audit of utility systems largely helps, which are given below:

- Reducing the energy consumption with resultant reduction in electricity bills.
- Audit involves data collection, data verification and detailed analysis of the data.
- The analysis lead store commendations, which are short term (with minimum investment), medium term (with moderate investment) and long term (with capital expenditure).
- The cost benefit analysis of various energy conservation proposals enables managements to take decisions regarding implementation schedules.

Energy conservation is a worldwide objective to save the human being from possible disaster. Under the mandate of The Energy Conservation Act 2001, the Bureau of Energy Efficiency and Government of India are implementing various programmes to provide momentum of the energy conservation movement in the country. Energy Auditing is most vital part of the conservation of energy. In order to improve the efficiency of the Energy consuming system, energy auditing is the first necessary action to be taken by the concerned firm. Through the energy auditing actual parameters can be detected at each step, which can be compared with the standard achievable parameters. For proper Energy auditing and energy accounting, parameters need to be monitored on regular.

Govt. PG College, Guna has engaged **SEES ENERGY SOLUTION**. for conducting detailed energy audit in their premises for the year of 2022-23.

1.2 Methodology & Approach

The audit involved basic design data collection for various electrical & thermal utilities, kick of meeting with concern departmental engineers & managers, carrying out various field measurements, performance analysis and loss analysis covering all major energy consuming sections of **Govt. PG College, Guna**. to realistically assess losses mainly in energy consuming utility areas and potential for energy savings. The major areas of study include:

- Building energy bills analysis.
- Electrical supply and distribution system analysis
- Lighting system analysis.
- Water pumping system analysis.
- Buildings envelop analysis.
- Specific Energy Consumption.

During study several interactions was made to the office personnel and technicians to share the actual operational features of equipment, equipment's maintenance schedule and equipment breakdown, down



time of machineries, safety measures etc. At the same time required data was collected from the various departments and review the same with the operational actual data.

The study focused on improving energy use efficiency and identifying energy saving opportunities at various equipment's. The analyses included simple payback period and life cycle cost calculations where investments are required to be made to implement recommendations, to establish their economic viability.

1.3 Instrument used in Energy Audit:

We have a wide array of latest, sophisticated, portable, diagnostic and measuring instruments to support our energy audit investigations and analyses. The audit study made use of various portable instruments along with plant online instrumentations, for carrying out various measurements and analyses. The specialized instruments that were used during the energy audit include:

- Power Analyzer.
- Ultra-Sonic Flow Meter.
- Digital power clamp meter & multi-meter (4545 MECO)
- Digital Hygrometer 625 TESTO
- Digital Lux Meter (LX-101A HTCTM)
- Digital Anemometer (AVM -07HTC)
- IR Thermometers for temperature measurement FLUKE 61 (IR -50 to 1550°C)
- Digital distance meter
- Measuring Tap meter



CHAPTER-2

SITE VISIT AND INSPECTION

2.1 College Details

Govt. Post Graduate College, Guna (M.P.) affiliated to Jiwaji University Gwalior is one of the most prestigious colleges of Gwalior division. Keeping the motto always in mind the college makes every effort to achieve excellence in academics and co-curricular activities.

The college which was established in 1957 and having faculties like arts, commerce & science.

VISION:

To provide the students quality education and to develop their personality by imparting moral education to them so as to make them responsible citizens of the country who can contribute effectively in nation building and social upliftment besides choosing a good profession.

MISSION:

- To provide excellent up-to-date knowledge to the students.
- To develop the personality of the students through extracurricular and sports activities.
- To strengthen the existing teaching learning methods to achieve excellence in Higher Education.
- To expand and strengthen the research facilities beneficial for all.

2.2 Site visit and field inspection

Energy audit team visited at college campus premises and also had completed of electrical measurement and appliances data collection.



Figure 2. Law College Building



Figure 3. B-Block & Library Building



Figure 4. Lux Level Reading Measurement at site



2.3 Power Measurement

Power measurement was done in the campus by the audit team. Power is measured at the transformer section.



Figure 5. Different Meters in College Building

Power is also measured at the Panels. The figure below shows the reading on the panels which was also measured by the auditor.



CHAPTER-3

ELECTRICITY BILL ANALYSIS

Govt. PG College, Guna receives power from, Madhya Pradesh Madhya Kshetra Vidyut Vitran Company Limited.

3.1 Month Wise Energy Consumption

The maximum demand, energy consumption, fixed charges, energy charges and total bill in **Rs. 832447** for the academic year 2022-2023 are showing below tables as per the details from the College bill. All the one year's data has been represented by the various graphs. This indicator addresses energy consumption, energy sources, energy monitoring, and electricity consumption.

Tariff Schedule LV - 2

NON-DOMESTIC:

LV 2.1

Applicability:

This tariff is applicable for light, fan and power to Schools / Educational Institutions including workshops and laboratories of Engineering Colleges / Polytechnics/ITIs (which are registered with /affiliated/ recognized by the relevant Govt. body or university), Hostels for students or working women or sports persons.

Tariff:

Tariff shall be as given in the following table:

| Sub category | Energy Charge (paise/unit) Urban/ Rural areas | Monthly Fixed Charge (Rs.) | |
|--|--|---|---|
| | | Urban areas | Rural areas |
| Sanctioned load-based tariff (only for connected load up to 10 kW) | 630 | 150 per kW | 120 per kW |
| Demand based tariff Mandatory for Connected load above 10 kW | 630 | 270 per kW or 216 per kVA of billing demand | 230 per kW or 184 per kVA of billing demand |

Figure 6. Electricity Tariff 2022-23



Table 4 Electricity Bill -1 Govt. P.G. College, IVRS- N2419054591

| Monthly Electricity bill Govt. P.G. College Guna. - 2022-23 IVRS-N2419054591 | | | | | | | | |
|--|----------------------|-------|---------|--------------------|---------------------|--------------|-----------------|---------------------------------|
| Months | Sanctioned Load (kW) | MDI | kWh | Fixed charges (Rs) | Energy Charges (Rs) | Power Factor | Total bill (Rs) | Average Per unit Charges Rs/kWh |
| Aug-22 | 41.3 | 27.96 | 5477.8 | 9075 | 35605.7 | 0.98 | 42043.66 | 7.7 |
| Sep-22 | 41.3 | 29.36 | 4737.6 | 9075 | 30794.8 | 0.98 | 37599.02 | 7.9 |
| Oct-22 | 41.3 | 30.9 | 5349 | 9075 | 32654.6 | 0.96 | 41729.60 | 7.8 |
| Nov-22 | 41.3 | 32.4 | 3277 | 9075 | 33162.2 | 0.97 | 42237.20 | 12.9 |
| Dec-22 | 41.3 | 34 | 3684 | 9075 | 35584.8 | 0.96 | 44659.80 | 12.1 |
| Jan-23 | 41.3 | 33.7 | 3777 | 9075 | 34854.5 | 0.95 | 43929.50 | 11.6 |
| Feb-23 | 41.3 | 31.5 | 4612 | 9075 | 34253.2 | 0.95 | 43328.24 | 9.4 |
| Mar-23 | 41.3 | 17.56 | 3651.8 | 9075 | 23736.7 | 0.95 | 32804.39 | 9.0 |
| Apr-23 | 41.3 | 24.52 | 4778 | 9075 | 31057.9 | 0.96 | 39795.62 | 8.3 |
| Jun-23 | 41.3 | 36.2 | 5895.2 | 9900 | 38318.8 | 0.96 | 48077.24 | 8.2 |
| Jul-23 | 41.3 | 38.12 | 6670.6 | 10450 | 43358.9 | 0.95 | 62921.96 | 9.4 |
| Aug-23 | 41.3 | 34.4 | 6282 | 9350 | 40833 | 0.97 | 57396.08 | 9.1 |
| Sep-23 | 41.3 | 32.4 | 4733.6 | 9075 | 30768.4 | 0.98 | 46477.12 | 9.8 |
| | | | 62925.6 | | | | 582999.4 | |




Figure 7. Per Unit Charges of IVRS- N2419054591



Table 5 Electricity Bill -2 Govt. P.G. College, Guna IVRS- N2419058383

| Monthly Electricity bill Govt. P.G. College Guna. - 2022-23 IVRS-N2419058383 | | | | | | | | |
|--|----------------------|-----|-------|--------------------|---------------------|--------------|-----------------|---------------------------------|
| Months | Sanctioned Load (kW) | MDI | kWh | Fixed charges (Rs) | Energy Charges (Rs) | Power Factor | Total bill (Rs) | Average Per unit Charges Rs/kWh |
| Aug-22 | 9 | 1 | 117 | 1404 | 760.5 | 0.8 | 2176.2 | 18.6 |
| Sep-22 | 9 | 1 | 117 | 1404 | 760.5 | 0.8 | 2176.2 | 18.6 |
| Mar-23 | 9 | 4 | 1263 | 1404 | 8209.5 | 0.7 | 10906.81 | 8.64 |
| Apr-23 | 9 | 4 | 1909 | 1404 | 12408.5 | 0.9 | 14135.12 | 7.40 |
| May-23 | 9 | 3 | 1387 | 1404 | 9015.5 | 0.9 | 10686.77 | 7.70 |
| Jun-23 | 9 | 11 | 1742 | 1716 | 11323 | 0.9 | 13684.38 | 7.86 |
| Jul-23 | 9 | 11 | 2317 | 1716 | 15060.5 | 0.9 | 16792.55 | 7.25 |
| Aug-23 | 9 | 11 | 2144 | 1716 | 13936 | 0.8 | 15584.11 | 7.27 |
| Sep-23 | 9 | 11 | 790 | 1716 | 5135 | 0.8 | 6551.39 | 8.29 |
| | | | 11786 | | | | 92693.53 | |




Figure 8. Per Unit Charges of IVRS- N2419058383



Table 6 Electricity Bill -2 Govt. PG College, Guna IVRS-N2419014551

| Monthly Electricity bill Govt. . P.G. College Guna. - 2022-23 IVRS-N2419014551 | | | | | | | | |
|--|----------------------|-----|------|--------------------|---------------------|--------------|-----------------|---------------------------------|
| Months | Sanctioned Load (kW) | MDI | kWh | Fixed charges (Rs) | Energy Charges (Rs) | Power Factor | Total bill (Rs) | Average Per unit Charges Rs/kWh |
| Aug-22 | 4.65 | 2.1 | 140 | 780 | 910 | 0.8 | 2286 | 16.33 |
| Sep-22 | 4.65 | 2.2 | 140 | 780 | 910 | 0.89 | 2267.52 | 16.20 |
| Mar-23 | 4.65 | 5 | 294 | 780 | 1911 | 0.8 | 2790.96 | 9.49 |
| Apr-23 | 4.65 | 4 | 640 | 780 | 4160 | 0.7 | 5595.35 | 8.74 |
| May-23 | 4.65 | 3 | 890 | 780 | 5785 | 0.8 | 6890.39 | 7.74 |
| Jun-23 | 4.65 | 0 | 608 | 780 | 3952 | 0.8 | 5064.36 | 8.33 |
| Jul-23 | 4.65 | 0 | 713 | 780 | 4634.5 | 0.8 | 6403.07 | 8.98 |
| Aug-23 | 4.65 | 3 | 2027 | 780 | 13175.5 | 0.76 | 15636.6 | 7.71 |
| Sep-23 | 4.65 | 3 | 582 | 780 | 3783 | 0.95 | 5232.19 | 8.99 |
| | | | 6034 | | | | 52166.44 | |




Figure 9. Per Unit Charges of IVRS-N2419014551



3.2 Observations & Comments:

- It is observed that, **Total Sanction load is 81 kW with Nos. 8 of connection** in College premises.
- As per electricity bills observation and analysis from **electricity unit (kWh) consumed 92067 kWh** for electricity bill in college premises.
- As per electricity bills observation and analysis **Total 12-month bill Paid is Rs. 832447.00.**
- As per electricity bills observation and analysis, **electricity bill Power Factor varies from 0.81-0.99.**



CHAPTER - 4

LIGHTING SYSTEM

4.1 Lighting Fixtures:

The Govt. PG College, Guna has high lighting load and various type of indoor and outdoor lighting fixture are installed in college campus. The lux measurement was also done at the time of audit. All the parameters are given in the below table:

Table 7. Different type of lighting fixture:

| Govt. P.G. College, Guna. | | | | | | | |
|---------------------------|--------------|------------------------|-------------------|-------------------------|-----------|-----------------|-----------|
| Sr. No. | Location | Location of Fixtures | Types of Lighting | No. of Lighting fixture | Power (W) | Total Power (W) | Lux Level |
| 1 | Ground Floor | Principle cabin | LED Round | 18 | 12 | 216 | 125-165 |
| | | Account Section | Tubelight | 3 | 20 | 60 | 80-98 |
| | | Account Section | FTL | 2 | 40 | 80 | 80-98 |
| | | Account Section | LED Bulb | 1 | 12 | 12 | 80-98 |
| | | Office | Tubelight | 6 | 20 | 120 | 130-160 |
| | | General Physics | Tubelight | 3 | 20 | 60 | 75-100 |
| | | General Physics | FTL | 2 | 40 | 80 | 75-100 |
| | | Professor & Head Cabin | Tubelight | 3 | 20 | 60 | 109-122 |
| | | Professor & Head Cabin | FTL | 1 | 40 | 40 | 109-122 |
| | | Room No.1 | LED | 8 | 20 | 160 | 110-130 |
| | | Corridor | Tubelight | 4 | 20 | 80 | 125-140 |
| | | Hall No. 30 | FTL | 12 | 40 | 480 | 120-140 |
| | | Hall No. 30 | LED Flood | 2 | 100 | 200 | 120-140 |
| | | Corridor - 2 | Tubelight | 7 | 20 | 140 | 125-140 |
| | | Store | Tubelight | 4 | 20 | 80 | 140-160 |
| | | Hindi Dept. | Tubelight | 3 | 20 | 60 | 110-135 |
| | | Room No.1 | FTL | 4 | 40 | 160 | 50-115 |
| | | Room No.2 | FTL | 4 | 40 | 160 | 50-115 |
| | | Room No.3 | FTL | 4 | 40 | 160 | 50-115 |
| | | Girls Room. | Tubelight | 2 | 20 | 40 | 140-160 |
| | | Girls Room. | FTL | 1 | 40 | 40 | 140-160 |
| | | Computer Room | Tubelight | 2 | 20 | 40 | 120-140 |
| | | Computer Room | FTL | 2 | 40 | 80 | 120-140 |
| | | Exam Control Room | Tubelight | 4 | 20 | 80 | 110-130 |
| | | Seminar Hall | LED Round | 40 | 12 | 480 | 98-114 |
| | | Chemistry HOD | Tubelight | 10 | 20 | 200 | 160-180 |
| | | Chemistry Lab | Tubelight | 11 | 20 | 220 | 80-90 |
| | | M.Sc. Lab | Tubelight | 10 | 20 | 200 | 85-105 |



| | | | | | | | | | |
|------------|-------------|--------------------------|-----------|----------------|-----------|-----|---------|-----|---------|
| | | B.Sc. Lab | Tubelight | 10 | 20 | 200 | 90-110 | | |
| | | Botany Lab | LED Bulb | 14 | 15 | 210 | 126-140 | | |
| | | Botany HOD Room | Tubelight | 4 | 20 | 80 | 126-140 | | |
| | | Geography Room | Tubelight | 8 | 20 | 160 | 180-225 | | |
| | | Psychology Room | Tubelight | 8 | 20 | 160 | 180-225 | | |
| | | Room No. 7 | FTL | 6 | 40 | 240 | 140-160 | | |
| | | Room No. 8 | FTL | 6 | 40 | 240 | 120-140 | | |
| | | Room No. 9 | FTL | 6 | 40 | 240 | 120-140 | | |
| | | Room No. 10 | FTL | 6 | 40 | 240 | 110-130 | | |
| | | Corridor | Tubelight | 3 | 20 | 60 | 110-130 | | |
| | | हिंदी शोध केंद्र | Tubelight | 4 | 20 | 80 | 90-110 | | |
| 2 | First Floor | Class Room No 11 | Tubelight | 6 | 20 | 120 | 140-160 | | |
| | | Class Room No 12 | Tubelight | 6 | 20 | 120 | 140-160 | | |
| | | Class Room No 13 | Tubelight | 6 | 20 | 120 | 140-160 | | |
| | | Class Room No 14 | Tubelight | 6 | 20 | 120 | 135-150 | | |
| | | Class Room No 15 | Tubelight | 6 | 20 | 120 | 135-150 | | |
| | | Class Room No 16 | Tubelight | 6 | 20 | 120 | 140-160 | | |
| | | Class Room No. 17 | FTL | 7 | 40 | 280 | 225-250 | | |
| | | Class Room No. 18 | Tubelight | 6 | 20 | 120 | 40-50 | | |
| | | Class Room No. 19 | Tubelight | 6 | 20 | 120 | 40-50 | | |
| | | Class Room No. 20 | Tubelight | 6 | 20 | 120 | 40-50 | | |
| | | Class Room No. 21 | FTL | 6 | 40 | 240 | 80-120 | | |
| | | Class Room No. 22 | FTL | 6 | 40 | 240 | 80-120 | | |
| | | Class Room No. 23 | FTL | 6 | 40 | 240 | 80-120 | | |
| | | Class Room No. 24 | FTL | 6 | 40 | 240 | 80-120 | | |
| | | Class Room No. 25 | FTL | 6 | 40 | 240 | 80-120 | | |
| | | Class Room No. 26 | FTL | 6 | 40 | 240 | 80-120 | | |
| | | Class Room No. 27 | FTL | 6 | 40 | 240 | 80-120 | | |
| | | Zoology Lab | Tubelight | 5 | 20 | 100 | 100-120 | | |
| | | HOD | Tubelight | 5 | 20 | 100 | 110-130 | | |
| | | M.sc. Lab | Tubelight | 6 | 20 | 120 | 80-100 | | |
| | | B.Sc. Lab | Tubelight | 6 | 20 | 120 | 80-100 | | |
| | | B Sc. Lab | LED Bulb | 5 | 15 | 75 | 80-100 | | |
| | | Biotech | Tubelight | 6 | 20 | 120 | 110-130 | | |
| | | Biotech | LED Bulb | 5 | 15 | 75 | 110-130 | | |
| | | | | IQAC Dept | Tubelight | 5 | 20 | 100 | 120-140 |
| | | | | Political Dept | Tubelight | 4 | 20 | 80 | 90-115 |
| | | | | Room No. 1 | Tubelight | 12 | 20 | 240 | 140-160 |
| Room No. 2 | Tubelight | | | 12 | 20 | 240 | 140-160 | | |
| Room No. 3 | Tubelight | | | 12 | 20 | 240 | 140-160 | | |
| Room No. 4 | Tubelight | | | 12 | 20 | 240 | 140-160 | | |
| Room No. 5 | Tubelight | | | 12 | 20 | 240 | 140-160 | | |
| Room No. 6 | Tubelight | | | 12 | 20 | 240 | 140-160 | | |
| | | LLB College (Room No. 1) | Tubelight | 2 | 20 | 40 | 43-60 | | |
| | | Room No. 2 | Tubelight | 2 | 20 | 40 | 43-60 | | |



| | | | | | | |
|--------------------------------------|-----------------------|-----------|---------------|----|-----|---------|
| | Room No. 3 | Tubelight | 2 | 20 | 40 | 43-60 |
| | Room No. 4 | Tubelight | 2 | 20 | 40 | 43-60 |
| | Room No. 5 | Tubelight | 2 | 20 | 40 | 43-60 |
| | Room No. 6 | Tubelight | 2 | 20 | 40 | 43-60 |
| | Library - Room. No. 1 | Tubelight | 8 | 20 | 160 | 90-110 |
| | Room No. 2 | Tubelight | 8 | 20 | 160 | 90-110 |
| | Room No. 3 | Tubelight | 8 | 20 | 160 | 90-110 |
| | Room No. 4 | Tubelight | 8 | 20 | 160 | 90-110 |
| | Room No. 5 | Tubelight | 8 | 20 | 160 | 90-110 |
| | Room No. 6 | Tubelight | 8 | 20 | 160 | 90-110 |
| | Corridor | Tubelight | 3 | 20 | 60 | 85-100 |
| | Sports Academy | Tubelight | 24 | 20 | 480 | 120-150 |
| Total Power Consumption in kW | | | 12.808 | | | |
| Total no. of Lighting Fixture | | | 557 | | | |

4.2 Observations & Comments:

- We appreciate to use **LED Lighting luminaries** at most of location as per site visit.
- We observed during visit, few Lights were FTL tube light consuming high electricity.
- We are suggesting to purchases all electrical equipment as per star leveling program by Bureau of energy. Efficiency, and will get huge amount of electricity saving.
- We are suggesting conducting regular **Cleaning and maintenance of lighting fixtures** in every 5-6 months. To increase performance of Lighting and also improve their Lux level.
- We will get energy saving approximately **5544 kWh** per year and also will get amount saving approximately **Rs. 5544** per year by replacing conventional T5 Tube light with new energy efficient LED Tube light .
- As per data collection and site visit, Total Connected lighting load at College Campus is **12.80 kW**.
- As per data collection and observation, **Total no. of lighting fixture is 557**.



LED TUBE LIGHT PROPOSAL

Proposal 1

Quotation for replacement of 105 Nos. existing 40 W FTL tube light with Energy efficient Energy Efficient 18 W LED Tube light in College.

| Energy Saving | |
|---|--------|
| Total no of Approximate 40 W FTL | 105 |
| Replacement of 40 Watt FTL with capacity of 18 Watt LED | 18 |
| Average daily running time for 40 Watt FTL in hour | 8 |
| Total Energy Consumed by 40 W FTL | 40 |
| Total Energy Consumed by 105 no. of 40 Watt FTL kWh per day | 33.6 |
| Annual Energy Consumed by 40 Watt FTL (300 working Days) kWh | 10080 |
| Annual Energy Consumed by 105 no. of 18 Watt LED in kWh | 4536 |
| Prospective Annual Energy Savings in kWh | 5544 |
| Annual Savings in Rupees (taking Average Rs. 10 Per unit charge for 300 day a year) | 55440 |
| Initial investment required for 105 no. of 18 Watt LED (Price for @ 500 per 18 Watt) | 52500 |
| Payback Period in months only | 11 |
| Life of the project years | 15 |
| Depreciation Cost Rs | 3500.0 |
| ROI {(Net annual savings – Depreciation cost)/ Investment} x 100% | 99 |



CHAPTER-5

FAN SYSTEM

There is various ceiling fan installed at various location in the **Govt. PG College, Guna** and they also contribute very high electricity consumption. All of the fans are conventional and hence high energy consuming.

5.1 Details of Different type off fans:

The detail of the fans is given in the below table:

Table 8. Different type of Fan

| Govt. P.G. College, Guna. | | | | | | |
|---------------------------|--------------|------------------------|--------------|-----------|-----------|-----------------|
| Sr. No. | Location | Location of Fan | Types of Fan | No.of Fan | Power (W) | Total Power (W) |
| 1 | Ground Floor | Principle cabin | Ceiling Fan | 4 | 70 | 280 |
| | | Account Section | Ceiling Fan | 2 | 70 | 140 |
| | | Office | Ceiling Fan | 3 | 70 | 210 |
| | | General Physics | Ceiling Fan | 4 | 70 | 280 |
| | | Professor & Head Cabin | Ceiling Fan | 2 | 70 | 140 |
| | | Room No.1 | Ceiling Fan | 6 | 70 | 420 |
| | | Corridor | Ceiling Fan | 1 | 70 | 70 |
| | | Hall No. 30 | Ceiling Fan | 12 | 70 | 840 |
| | | Store | Ceiling Fan | 2 | 70 | 140 |
| | | Hindi Dept. | Ceiling Fan | 2 | 70 | 140 |
| | | Room No.1 | Ceiling Fan | 3 | 70 | 210 |
| | | Room No.2 | Ceiling Fan | 3 | 70 | 210 |
| | | Room No.3 | Ceiling Fan | 3 | 70 | 210 |
| | | Girls Room. | Ceiling Fan | 1 | 70 | 70 |
| | | Exam Control Room | Ceiling Fan | 6 | 70 | 420 |
| | | Seminar Hall | Ceiling Fan | 8 | 70 | 560 |
| | | Chemistry HOD | Ceiling Fan | 4 | 70 | 280 |
| | | Chemistry Lab | Ceiling Fan | 2 | 70 | 140 |
| | | Chemistry Lab | Exhaust Fan | 2 | 150 | 300 |
| | | M.Sc. Lab | Ceiling Fan | 2 | 70 | 140 |
| | | B.Sc. Lab | Ceiling Fan | 2 | 70 | 140 |
| | | Botany Lab | Ceiling Fan | 3 | 70 | 210 |
| | | Botany HOD Room | Ceiling Fan | 4 | 70 | 280 |
| | | Geography Room | Ceiling Fan | 9 | 70 | 630 |
| | | Psychology Room | Ceiling Fan | 9 | 70 | 630 |
| | | Room No. 7 | Ceiling Fan | 6 | 70 | 420 |
| | | Room No. 8 | Ceiling Fan | 6 | 70 | 420 |
| | | Room No. 9 | Ceiling Fan | 6 | 70 | 420 |
| | | Room No. 10 | Ceiling Fan | 6 | 70 | 420 |
| | | हिंदी शोध केंद्र | Ceiling Fan | 9 | 70 | 630 |
| | | Class Room No 11 | Ceiling Fan | 6 | 70 | 420 |



| | | | | | | |
|--------------------------------------|--|--------------------------|-------------|--------------|----|------|
| | | Class Room No 12 | Ceiling Fan | 6 | 70 | 420 |
| | | Class Room No 13 | Ceiling Fan | 6 | 70 | 420 |
| | | Class Room No 14 | Ceiling Fan | 6 | 70 | 420 |
| | | Class Room No 15 | Ceiling Fan | 6 | 70 | 420 |
| | | Class Room No 16 | Ceiling Fan | 6 | 70 | 420 |
| | | Class Room No. 17 | Ceiling Fan | 11 | 70 | 770 |
| | | Class Room No. 18 | Ceiling Fan | 4 | 70 | 280 |
| | | Class Room No. 19 | Ceiling Fan | 4 | 70 | 280 |
| | | Class Room No. 20 | Ceiling Fan | 4 | 70 | 280 |
| | | Class Room No. 21 | Ceiling Fan | 6 | 70 | 420 |
| | | Class Room No. 22 | Ceiling Fan | 6 | 70 | 420 |
| | | Class Room No. 23 | Ceiling Fan | 6 | 70 | 420 |
| | | Class Room No. 24 | Ceiling Fan | 6 | 70 | 420 |
| | | Class Room No. 25 | Ceiling Fan | 6 | 70 | 420 |
| | | Class Room No. 26 | Ceiling Fan | 6 | 70 | 420 |
| | | Class Room No. 27 | Ceiling Fan | 6 | 70 | 420 |
| | | Zoology Lab | Ceiling Fan | 5 | 70 | 350 |
| | | HOD | Ceiling Fan | 5 | 70 | 350 |
| | | M.sc. Lab | Ceiling Fan | 6 | 70 | 420 |
| | | B.Sc. Lab | Ceiling Fan | 6 | 70 | 420 |
| | | Biotech | Ceiling Fan | 6 | 70 | 420 |
| | | IQAC Dept | Ceiling Fan | 4 | 70 | 280 |
| | | Political Dept | Ceiling Fan | 4 | 70 | 280 |
| | | Room No. 1 | Ceiling Fan | 9 | 70 | 630 |
| | | Room No. 2 | Ceiling Fan | 9 | 70 | 630 |
| | | Room No. 3 | Ceiling Fan | 9 | 70 | 630 |
| | | Room No. 4 | Ceiling Fan | 9 | 70 | 630 |
| | | Room No. 5 | Ceiling Fan | 9 | 70 | 630 |
| | | Room No. 6 | Ceiling Fan | 9 | 70 | 630 |
| | | LLB College (Room No. 1) | Ceiling Fan | 6 | 70 | 420 |
| | | Room No. 2 | Ceiling Fan | 6 | 70 | 420 |
| | | Room No. 3 | Ceiling Fan | 6 | 70 | 420 |
| | | Room No. 4 | Ceiling Fan | 6 | 70 | 420 |
| | | Room No. 5 | ceiling Fan | 6 | 70 | 420 |
| | | Room No. 6 | Ceiling Fan | 6 | 70 | 420 |
| | | Library - Room. No. 1 | Ceiling Fan | 9 | 70 | 630 |
| | | Room No. 2 | Ceiling Fan | 9 | 70 | 630 |
| | | Room No. 3 | Ceiling Fan | 9 | 70 | 630 |
| | | Room No. 4 | Ceiling Fan | 9 | 70 | 630 |
| | | Room No. 5 | Ceiling Fan | 9 | 70 | 630 |
| | | Room No. 6 | Ceiling Fan | 9 | 70 | 630 |
| | | Corridor | Ceiling Fan | 7 | 70 | 490 |
| | | Sports Academy | Ceiling Fan | 24 | 70 | 1680 |
| Total Power Consumption in kW | | | | 31.24 | | |
| Total no. of Fan Fixture | | | | 444 | | |



5.2 Observations & Comments:

- We observed that most of the Fans installed in campus were conventional.
- We are recommended to **replace 444 no. of 70 W Ceiling fan with New Super energy efficient 5 star rated BLDC ceiling fan** and will get huge amount of electricity saving as per Star leveling program by Bureau of Energy Efficiency.
- We are **Suggesting to purchases new energy efficient BLDC fan as per Star leveling program by Bureau of Energy Efficiency, and will get huge amount of electricity saving.**
- Energy Saving calculation **and recommendation for the existing Conventional** Ceiling fans with BLDC super energy efficient fan has been given in this report.
- We are suggesting **conducting regular Cleaning and maintenance** of Fan at least in every 6 months to increase performance of Fan.
- We are also suggesting improving their Air delivery of Fan by Replacing New energy efficient BLDC Fan as per 5 stars leveling of Bureau of energy efficiency.
- We will get energy saving approximately **44755 kWh** per year and also will get amount saving approximately **Rs. 447552.00** per year by replacing conventional Fan with new energy efficient BLDC fan.
- The total load for Ceiling Fan is **31.24 kW**.
- Total No. of Fan fixtures are **444**.



CEILING FAN PROPOSAL

Proposal 1

Replacement of 444 Nos. Existing 70 W Ceiling Fan with Energy efficient Energy Efficient 28 W BLDC Fan in College.

| Energy Saving | |
|---|---------|
| Total no of Approximate 70 W Ceiling Fan | 444 |
| Replacement of 70Watt Ceiling Fan with capacity of 28 Watt BLDC Fan | 28 |
| Average daily running time for 70 Watt Ceiling Fan in hour | 8 |
| Total Energy Consumed by 70 W Ceiling Fan | 70 |
| Total Energy Consumed by 444 no. of 70 Watt Ceiling Fan kWh per day | 248.64 |
| Annual Energy Consumed by 70 Watt Ceiling Fan (300 working Days) kWh | 74592 |
| Annual Energy Consumed by 444 no. of 28 Watt Ceiling Fan in kWh | 29837 |
| Prospective Annual Energy Savings in kWh | 44755 |
| Annual Savings in Rupees (taking Average Rs. 10 Per unit charge for 300 day a year) | 447552 |
| Initial investment required for 267no. of 28 Watt Ceiling Fan(Price for BLDC Fan @ 2800 per 28 Watt BLDC Fan) | 1243200 |
| Payback Period in months only | 33 |
| Life of the project years | 15 |
| Depreciation Cost Rs | 82880 |
| ROI {(Net annual savings – Depreciation cost)/ Investment} x 100% | 29 |



CHAPTER - 6

OTHER EQUIPMENTS LOAD

There are different types of other equipment's like Printer, PC, Water Cooler, Refrigerator and other lab equipment's are installed at various locations in the College, Indore and they also contribute electricity consumption.

6.1 Different Type Other Equipment's

Table 9. Different type of equipment system

| Other equipments location wise Govt. P.G. College, Guna. | | | | | | |
|--|----------|--------------------------|-----------------|-------------------|---------------|---------------------|
| Sr. No. | Location | Location of Product | Type of Product | Number of Product | Power (Watts) | Total Power (Watts) |
| 1 | | | PC | 61 | 100 | 6100 |
| | | | Printer | 6 | 650 | 3900 |
| | | | Fridge | 3 | 350 | 1050 |
| | | | Photocopier | 3 | 550 | 1650 |
| | | | Water cooler | 4 | 575 | 2300 |
| | | | LED TV | 2 | 66 | 132 |
| | | | Air Cooler | 4 | 500 | 2000 |
| | | | Projector | 1 | 575 | 575 |
| | | Total Power in kW | | | | |

6.2 Observations & Comments:

- Total Connected load **17.74 kW**.
- We suggest to **purchase Equipment's as per Star leveling program** by Bureau of Energy Efficiency 2020, and will get huge amount of electricity saving.
- Maintenance of all the equipment's should be done regularly.



CHAPTER -7

PUMPING SYSTEM

7.1 Submersible Pumps

There is 1 no. of 3 HP capacity of submersible pump installed within college campus for drinking water, Flushing and gardening purpose.




Table 10. Major usage area of pump

Pumps Details:

| Pump Details Govt. Girls College, Indore. | | | | | | |
|---|----------------|------------------|------------------|-------------|------------|------------------|
| Sr. No. | Location | Location of Pump | Types of Pumps | No. of Pump | Power (HP) | Total Power (KW) |
| 1 | College Campus | Back side | Submersible Pump | 1 | 3 | 4.50 |
| Total Power in kW | | | | | | 4.50 |

7.2 Observation and Comments:

- We observed during Energy Audit and site visit, **1 Pumps, of Capacity 3HP within** College campus for drinking water, Flushing and gardening purpose.
- Power consumption of 3 HP pump was **4.50 kW** as per site visit and measurement.
- We are suggesting purchasing **5 star rated pumps and will get huge** amount of saving as per Star leveling program by Bureau of Energy Efficiency2020.
- We are **suggesting installing Solar Pumping system and** will get huge amount of savings.



CHAPTER-08

GENERAL TIPS FOR ENERGY CONSERVATION IN DIFFERENT UTILITIES SYSTEMS

Electricity:

- Schedule your operations to maintain a high load factor
- Minimize maximum demand by tripping loads through a demand controller
- Use standby electric generation equipment for on-peak high load periods.
- Correct power factor to at least 0.99 under rated load conditions.
- Set transformer taps to optimum settings.
- Shut off unnecessary computers, printers, and copiers at night.

Motors:

- Properly size to the load for optimum efficiency.
- (High efficiency motors offer of 4 - 5% higher efficiency than standard motors)
- Check alignment.
- Provide proper ventilation
- (For every 10°C increase in motor operating temperature over recommended peak, the motor life is estimated to be halved)
- Check for under-voltage and over-voltage conditions.
- Balance the three-phase power supply.
- (An Imbalanced voltage can reduce 3 - 5% in motor input power)
- Demand efficiency restoration after motor rewinding.

Fans:

- Use smooth, well-rounded air inlet cones for fan air intakes.
- Avoid poor flow distribution at the fan inlet.
- Minimize fan inlet and outlet obstructions.
- Clean screens, filters, and fan blades regularly.
- Use aero foil-shaped fan blades.
- Minimize fan speed.
- Use variable speed drives for large variable fan loads.



Pumps:

- Operate pumping near best efficiency point.
- Modify pumping to minimize throttling.
- Adept to wide load variation with variable speed drives or sequenced control of smaller units.
- Stop running both pumps -- add an auto-start for an on-line spare or add a booster pump in the problem area.
- Use booster pumps for small loads requiring higher pressures.
- Increase fluid temperature differentials to reduce pump ingrates.
- Repair seals and packing to minimize water waste.
- Balance the system to minimize flows and reduce pump power requirements.
- Use siphon effect to advantage: don't waste pumping head with a free-fall (gravity) return.

Lighting:

- Reduce excessive illumination levels to standard levels using switching; decamping, etc. (Know the electrical effects before doing decamping.)
- Aggressively control lighting with clock timers, delay timers, photocells, and/or occupancy sensors.
- Install efficient alternatives to incandescent lighting, mercury vapor lighting, etc. Efficiency (lumens/watt) of various technologies range from best to worst approximately as follows: low pressure sodium, high-pressure sodium, metal halide, fluorescent, mercury vapor, incandescent.
- Select ballasts and lamps carefully with high power factor and long-term efficiency in mind.
- Upgrade obsolete fluorescent systems to Compact fluorescents and electronic ballasts
- Consider lowering the fixtures to enable using less of them.
- Consider day lighting, skylights, etc.
- Consider painting the walls a lighter color and using less lighting fixtures or lower wattages.
- Use task lighting and reduce back ground illumination.
- Re-evaluate exterior lighting strategy, type, and control. Control it aggressively.
- Change exit signs from incandescent to LED.

DG Sets:

- Optimize loading
- Use waste heat to generate steam/hot water /power an absorption chiller or preheat process or utility feeds.



- ❑ Clean air filters regularly
- ❑ Insulate exhaust pipes to reduce DG set room temperatures
- ❑ Use cheaper heavy fuel oil for capacities more than 1MW

Buildings:

- ❑ Seal exterior cracks/openings/gaps with caulk, gasketing, weather stripping ,etc.
- ❑ Consider new thermal doors, thermal windows, roofing insulation ,etc.
- ❑ Install windbreaks near exterior doors.
- ❑ Replace single-pane glass with insulating glass.
- ❑ Consider covering some window and skylight areas with insulated wall panels inside the building.
- ❑ If visibility is not required but light is required, consider replacing exterior windows with insulated glass block.
- ❑ Consider tinted glass, reflective glass, coatings, awnings, overhangs, draperies, blinds, and shades for sunlit exterior windows.
- ❑ Use landscaping to advantage.
- ❑ Add vestibules or revolving doors to primary exterior personnel doors.
- ❑ Use intermediate doors in stairways and vertical passages to minimize building stack effect.
- ❑ Use dock seals at shipping and receiving doors.
- ❑ Bring cleaning personnel in during the working day or as soon after as possible to minimize lighting and HVAC costs.

Waste & Waste water:

- ❑ Recycle water, particularly for uses with less-critical quality requirements.
- ❑ Recycle water, especially if sewer costs are based on water consumption.
- ❑ Balance closed systems to minimize flows and reduce pump power requirements.
- ❑ Eliminate once-through cooling with water.
- ❑ Use the least expensive type of water that will satisfy the requirement.
- ❑ Fix water leaks.
- ❑ Test for underground water leaks. (It's easy to do over a holiday shutdown.)
- ❑ Check water overflow pipes for proper operating level.



-
- Automate blow down to minimize etc.
 - Provide proper tools for wash down -- especially self-closing nozzles.
 - Install efficient irrigation.
 - Reduce flows at water sampling stations.
 - Eliminate continuous overflow at water tanks.
 - Promptly repair leaking toilets and faucets.
 - Use water restrictors on faucets, showers, etc.
 - Use self-closing type faucets in rest rooms.
 - Use the lowest possible hot water temperature.
 - Use freeze protection valves rather than manual bleeding of lines.
 - Consider leased and mobile water treatment systems, especially for deionized water.
 - Seal sumps to prevent seepage inward from necessitating extra sump pump operation.
 - Install pretreatment to reduce TOC and BOD surcharges.
 - Verify the water meter readings.(You'd be amazed how long a meter reading can be estimated after the meter breaks or the meter pit fills with water!)
 - Verify the sewer flows if the sewer bills are based on them.

Miscellaneous:

- Meter any unmetered utilities. Know what normal efficient use is. Track down causes of deviations.
- Shut down spare, idling, or unneeded equipment.
- Make sure that all of the utilities to redundant areas are turned off -- including utilities like cooling water.
- Install automatic control to efficiently coordinate, chillers, cooling tower cells, etc.
- Renegotiate utilities contracts to reflect current loads and variations.
- Consider buying utilities from neighbors, particularly to hand peaks.
- Minimize use of flow bypasses and minimize bypass flow rates.
- Consider alternatives to high-pressure drops across valves.
- Turn off winter heat tracing that is on in summer.



Annexure - 1

Standard Lux Level

| Activity | Illumination (lux, lumen/m ²) |
|---|--|
| Public areas with dark surroundings | 20 - 50 |
| Simple orientation for short visits | 50 - 100 |
| Working areas where visual tasks are only occasionally performed | 100 - 150 |
| Warehouses, Homes, Theaters, Archives | 150 |
| Easy Office Work, Classes | 250 |
| Normal Office Work, PC Work, Study Library, Groceries, Show Rooms, Laboratories | 500 |
| Supermarkets, Mechanical Workshops, Office Landscapes | 750 |
| Normal Drawing Work, Detailed Mechanical Workshops, Operation Theatres | 1,000 |
| Detailed Drawing Work, Very Detailed Mechanical Works | 1500 - 2000 |
| Performance of visual tasks of low contrast and very small size for prolonged periods of time | 2000 - 5000 |
| Performance of very prolonged and exacting visual tasks | 5000 - 10000 |
| Performance of very special visual tasks of extremely low contrast and small size | 10000 - 20000 |



Annexure - 2

Energy saver for air conditioning system



PATENT
PUBLISHED



Airtron is the World's First & Only Programmable, Dual-Sensor Driven Microprocessor which saves up to 35% Electricity on all Air Conditioners with Precision Control of Set Temperature and a payback of barely 4-6 months.

| IMPORTANT VALIDATIONS N.B. The Set Temp. was the Same WITH / WITHOUT the Airtron. | | | | |
|---|---|----------|---------------------|---------|
| SL. NO. | NAME OF THE COMPANY | COUNTRY | AC TYPE | SAVINGS |
| 1 | ENERGY EFFICIENCY SERVICES LTD . (EESL GOVT. OF INDIA) | INDIA | SPLIT | 44.00% |
| 2 | L.G. ELECTRONICS INDIA LTD. | INDIA | SPLIT (INVERTER) | 26.00% |
| 3 | VIDEOCON TELECOM | INDIA | SPLIT | 20.00% |
| 4 | TATA COMMUNICATION LTD. | INDIA | SPLIT | 28.30% |
| 5 | LARSEN & TOUBRO LTD. | INDIA | SPLIT | 25.80% |
| 6 | TATATELE SERVICES LTD. | INDIA | SPLIT | 33.00% |
| 7 | TATA POWER LTD. | INDIA | SPLIT | 37.50% |
| 8 | ASHOK LEYLAND LTD. | INDIA | WINDOW | 29.40 |
| 9 | ZENITH ENERGY (BEE, ACCREDITED ENERGY AUDITOR) | INDIA | SPLIT | 37.00% |
| 10 | ACCENTURE SERVICES PVT. LTD. | INDIA | SPLIT | 37.00% |
| 11 | M/S. UNIC MAGNATE | INDIA | SPLIT | 58.00% |
| 12 | SATURN PYRO (UTIM REGISTRATION OFFICE) | MALAYSIA | CEILING-SPLIT | 36.00% |
| 13 | SATURN PYRO (AT MALAYSIA POLICE H.Q.) | MALAYSIA | WALL -SPLIT | 34.00% |
| 14 | CPE ENERGY SDN BHD | MALAYSIA | SPLIT | 57.00% |



Annexure – 3

Super Energy efficient BLDC Ceiling Fan

| | 900 mm | 1050 mm | 1200 mm | 1400 mm |
|---------------------------------|---|---------|---------|---------|
| Warranty (Years) | 3 Years | 3 Years | 3 Years | 3 Years |
| Blade Span (mm/inch) | 900/36 | 1050/42 | 1200/48 | 1400/56 |
| RPM | 450 | 430 | 350 | 270 |
| Service Value | 7.1 | 6.6 | 7.8 | 7.7 |
| Input Voltage (V) | 140-285 | 140-285 | 140-285 | 140-285 |
| Power Consumption (W) | 28 | 32 | 28 | 35 |
| Frequency (Hz) | 48-52 | 48-52 | 48-52 | 48-52 |
| Air Delivery (CMM) | 200 | 210 | 220 | 270 |
| Power Factor | >0.98 | >0.98 | >0.98 | >0.99 |
| No. of Blades | 3 | 3 | 3 | 3 |
| Bearing (Double) | Deep Groove Double Sided Steel Shielding | | | |
| Remote Control (12 Keys) | Speed Control, Boost Mode, Timer and Sleep Mode | | | |





Comparison Between Ordinary, 5 Star Rated and Super-Efficient Fans

| Parameters | Ordinary Fan | 5 Star Rated Fan | Super-Efficient Fan |
|--------------------|--------------|------------------|----------------------------------|
| Wattage | 75 | 50 | 28 |
| RPM (speed) | 380 | 330 | 360-380 |
| CMM (air delivery) | 230 | 210 | 220-230 |
| Power factor | >0.9 | >0.95 | >0.99 |
| Regulator | Yes | Yes | Not Required (Remote controlled) |
| Input Voltage | 230 | 230 | 140-285V |
| Warranty | 1-2 year | 1-2 year | 3 years |
| MRP | 1300-1600 | 1800-2500 | 3690 |